

Office of the Director

**Dr. Bhubaneswar Borooah Cancer Institute**

A Grant-in-Aid Institute of Department of Atomic Energy, Govt. of India  
and a unit of Tata Memorial Centre (Mumbai)  
Gopinath Nagar, Guwahati- 781016

\*\*\*\*\*

No. BBCI-TMC/IT-12/ 1381 /2022

Date: 01.04.2022

**SHORT TENDER**

Dr. B. Borooah Cancer Institute, Gopinath Nagar, Guwahati- 781016 invites quotations from authorized vendors to provide offers of the following service:

Sl. No.	Particulars	Estimated Quantity
1.	<b>Supply, installation, fitting &amp; commissioning of 42U Server Rack</b> (See technical specifications in Annexure-A)	01 No.

1. The quotation must be in the same order as in the specifications and should be free from Correction / erasures. In case there is any unavoidable correction it should be properly attached. If not, the quotation will not be considered. Quotations written in pencil will not be considered.
2. The vendor should provide authorization letter along with their offer.
3. The quotation shall be submitted in one sealed form at Dr. BBCI office and this will be received up to **2:00 PM of 13.04.2022** and the same will be opened on the same day at **3:00 PM**.
4. The quotation must accompany the Product details.
5. The above mentioned quantities are tentative only; the supply orders of respective items will be given as per actual requirement.
6. Director, Dr. B. Borooah Cancer Institute reserves the right to accept the offer by individual terms and reject any or all tenders without assigning any reason thereof and does not bind itself to accept lowest quotations.
7. Please mention the make/brand and model of the quoted product. Also submit necessary leaflet of the quoted product.
8. The quotation notice number must be clearly mentioned on the envelope.
9. The valid technical offers will be evaluated by a Technical Assessment Committee (TAC) of the Institute. The TAC will recommend the technically short listed vendors for further consideration. The offers of the technically short listed vendors/products will only be considered for price comparison.
10. The successful quotationer shall have to supply the materials to this institute at his own risk and responsibility and in good condition in all respects.
11. The quotation notice is to be duly signed on all pages as a token of having accepted all terms and conditions (no thumb impression is to be affixed).

12. The price should be quoted in the following format which should be inclusive of all charges. Taxes, if any, should be shown separately. However, GST will be paid to the successful vendor at prevailing rate at the time of billing/ payment.

SL No	Item	Unit Price(Rs.)	Qty.	Amount before GST (RS.)	GST %	Any other taxes, if applicable	Grand Total (after GST) (Rs.)

13. The quotation shall include delivery time, payment terms, etc. and other relevant T & C.
14. The vendors should provide all the related documents for the verification of compliance that will be filled in respect of the quoted model.
15. The rate should be quoted both in figure and in words.
16. Payment terms: Payment will be made within 60 (sixty) days of submission of bill after successful supply, installation, fitting & commissioning of the items.
17. Incomplete quotation not in conformity with the terms and conditions as in this quotation notice will be rejected outright.
18. Decisions of the Technical Assessment Committee/ Purchase Committee/ any other committee constituted by the authority of Dr. B. Borooah Cancer Institute shall be final and binding in all cases.
19. The tender shall be valid for a period of 180 days from the date of the opening of the bid. Validity of the tender shall be extended if required.

*BSL/A 1/9/22.*  
**Sr. Administrative Officer**  
Dr. B. Borooah Cancer Institute  
Guwahati- 781016

Copy to:

1. BBCI website [www.bbcionline.org](http://www.bbcionline.org)
2. BBCI Notice Board

**Technical Specifications for 42U Server Rack**

1. Top and bottom Panel with ventilation and cable entry facility
2. Adjustable 19" equipment mounting verticals for providing better mounting flexibility maximizing the usable mounting space
3. Provision to mount the cooling fans on the top panel
4. Depth adjustable mounting slots
5. Powder coated finish with pretreatment process meeting all industry standards
6. Power Distribution Unit- Two Number dual input Vertically Mounted 230 Volt PDU, 32AMPs with 25 power outputs with 25 (20 nos. Power outs of IEC 320 C13 Sockets & 5 nos. Power outs of 6/16 amps Sockets)
7. Vertical Cable Manager 1Ux42U
8. Horizontal Cable Manager- 1U-Loop
9. Colour of the rack should be black

**Standard Accessories:**

1. Both side door and side panel & it should be openable
2. Power Distribution Units
3. Cable Managers
4. Fans and Fan Modules
5. Jacking Feet
6. Mounting Hardware
7. Cantilever Tray for Modem
8. Earthing Kit

**All installation, fitting and commissioning of 42U rack is to be done by the vendor in BBCI datacentre**