

Office of the Director

DR. BHUBANESWAR BOROOAH CANCER INSTITUTE

A grant-in-aid institute of Department of Atomic Energy, Govt. of India

And a unit of Tata Memorial Centre (Mumbai)

Gopinath Nagar, Guwahati- 781016

No- BBCI-TMC/Eng-179/1527 /2022


Date: 11/04/2022

CORRIGENDUM

The technical specifications for supply, installation & commissioning of "100Nos. of 1KVA online UPS" at Dr. B. Borooah Cancer Institute against NIT No.BBCI-TMC/Equip-179/1494/2022, dtd.08.04.2022 is as follows:


Sl. No	As published in tender documents	Amendment
1.	Battery Parameters.SI No:3- DCbus voltage,36VDC	DC bus voltage,24VDC
2.	Battery Parameters.SI No:5- Number of Batteries-03nos.	Numbers of batteries-02nos.
3.	Physical and Environment Characteristics.SI No:6- Dimension(D X W X H) in MM	This point is deleted.
4.	(-)	Warranty:2 years on UPS as well as batteries

The other specifications and terms & conditions of the NIT shall remain unchanged.


Deputy Director(Admin)
Dr. B. Borooah Cancer Institute
Guwahati – 16

Copy for information to:

1. BBCI website www.bbcionline.org
2. Notice Board, BBCI
3. Concerned file


Deputy Director(Admin)
Dr. B. Borooah Cancer Institute
Guwahati – 16